

CLIMBING PRECAUTIONS

1. GENERAL

1.001 This addendum supplements Section 460-300-110, Issue 1.

1.002 This addendum is issued to clarify whether or when a pole can be climbed if a B or C pole tag has been affixed to a pole.

2. POLES—PRECAUTIONS AND TESTING

The following change applies to Part 2 of this section.

- (a) Add the following information to paragraph 2.28:

It serves as a warning to workmen that the pole is defective and should *not* be

climbed or worked on without following the recommendations of Section 620-132-010, entitled Safeguards To Be Taken Before Climbing Poles—Testing Poles.

- (b) Add the following information to paragraph 2.29:

It serves as a warning to workmen that the pole is in a dangerous condition and should not be climbed or worked on before being temporarily supported as described in Section 620-133-010 entitled Safeguards To Be Taken Before Climbing Poles—Temporary Supports.